

SECURITY GUARD PROCEDURES
FOR
FIRE IN BEECH MT. LAKES

In the case of a Fire in the Beech Mountain Lakes Community, the Security Guard will notify the Water Company Personnel AS SOON AS THEY FIND OUT THE FIRE COMPANY HAS BEEN DISPATCHED OR IS BEING DISPATCHED TO BMLA. They place the call in this order to:

Water Company Office: 788-6951

Ed's pager: 453-7056

Mike's pager: 453-7057

Security will advise the Water Company personnel as to the place and nature of the Fire Call Out.

The reason for the Water Company personnel to be contacted is to monitor the water storage and the system.

The Hydrants used by the Fire Company are not FIRE Hydrants and are use by the Water Company for their MAINTENANCE OF THEIR LINES. However, the Water Company has agreed to allow the Fire Company to utilize these hydrants as a water source, but in doing this they make no commitment to their use as FIRE HYDRANTS, AS THEY ARE NOT FIRE HYDRANTS.

The Water Company will assist the Fire Company in determining where and which hydrants to use in fighting the fire. This procedure should aid the Fire Fighters in establishing a proper water source in close range to the fire. Also, will ensure an adequate and proper supply is available.

Should this program fail and the Water Company Personnel are not available in a timely fashion. The Fire Company can start to pull water from the Lake or the Pond (on Bear Run) until a working fire hydrant in close range to the fire is established.

A list of Non-Functioning Fire Hydrants shall be maintained at the Security Guard Building.

updated 21 March 03

Security Gaurds Procedures
For
Fie in Beech Mt. Lakes

In the case of fire in the Beech Mountain Lakes Community, the Security guard will notify the Water Company Personnel AS SOON AS THEY FIND OUT THE FIRE COMPANY HAS BEEN DISPATCHED OR IS BEING DISPATCHED TO BMLA.

They place the call in this order:

Water Company Office (570) 636-0570 during working hours
After Hours Answering Service 225-338-6360

Ed. Nahay Cell 233-5359

Shawn Cell 233-5358

Security will advise the Water Company personnel as to place and nature Of the fire call out.

Thje reason for the water Company personnel to be contacted is to monitor Water storage and the system.

The hydrants used by the Fire Company are not FIRE Hydrants and are used By the Water Company for the MAINTANCE OF THEIR LINES. However The Water Company has agreed to allow the Fire Company to utilize these Hydrants as a water source, but in doing so they make no commitment to their Use as FIRE HYDRANTS ,AS THEY ARE NOT FIRE HYDRANTS.

The Water Company will assist the Fire Company in determining where and Which Fire Hydrants to use in the fighting the fire. This procedure should aid The firefighters in establishing a proper water source in close range to the fire. Also will insure a adequate and proper supply is available.

Should this program fail and the Water Company personnel are not available In a timely fashion. The Fire Company can start to pull water from the lake Or the pond (on Bear Run) until a working fire hydrant in close range to the Fire is established.

A list of non-functioning hydrants shall be maintained at the security office.